


**TEST REPORT NUMBER:** PRTT00075961 Page 1 of 4  
**APPLICANT:** GOYA IMPORTACIONES Y DISTRIBUCIONES, SL. **DATE OF EMISSION:** 17/07/2020  
CALLE TRAPANI (PLATAFORMA LOGISTICA  
PLA-ZA. EDIF. GOYA), No. 27 - ZARAGOZA, SPAIN  
50197

**SAMPLE DESCRIPTION:** Type Mask : Social Masks Hygienic Mask UNE 0065  
Reference : 50566  
Colour : Varios  
Type and Composition of Material : First and third layer - cotton Middle layer - Melt Blown  
Supplier : Goya Importaciones Y Distribuciones SL  
1 - Social Masks  
**DATE OF RECEPTION:** 02/07/2020  
**TEST PERFORMED BETWEEN DATES:** 02/07/2020 and 17/07/2020  
**WORK DAYS:** 12  
**REQUEST:** Tests performed in accordance with SUPPLIER TEST REQUEST specification  
**NOTES:**

**Samples**

Test	1
*‡ BFE (FILTRATION)	M
*‡ DIFFERENCIAL PRESSURE (BREATHABILITY)	M

M = Meet buyer's requirement; NM = does not meet buyer's requirement; NR = Not requested; NA = Not applicable; NC = No comment; SC = Still continues  
- Test results relate only to submitted items. The report shall not be reproduced except in full, without the written approval of Intertek Portugal.  
- Tests marked by (\*) are not included in the scope of IPAC accreditation for this Laboratory.  
- Tests marked by (‡) have been sub-contracted by Intertek Portugal to an accredited laboratory.  
- Tests marked by (\*‡) are not included in the scope of IPAC Accreditation and have been sub-contracted by Intertek Portugal.  
Consult our terms and conditions on <http://www.intertek.pt/termos-e-condicoes/>.

  
\_\_\_\_\_  
Textiles Laboratory Manager  
ana.morgado@intertek.com

---

Test Method	Results	Requirements
-------------	---------	--------------

---

**\*‡ BFE (FILTRATION)**

EN 14683:2019+AC 2019

Sample: 1

Acceptable result =>90%

RESULT

95.4%

Test Conditions:

Temperature: 21±5°C Humidity: 75±5%

Dimensions of the test specimens: 4.9cm<sup>2</sup> (5 test specimens)

Side of the test specimen facing the challenge aerosol: intern

Air flow rate: 28.3 l/min.

MPS 2.8

Test specimen 1 (95.5%), Test specimen 2 (95.8%), Test specimen 3 (95.8%),

Test specimen 4 (95.0%), Test specimen 5 (95.0%).

Expanded uncertainty = 0.16% (based on a standard uncertainty multiplied by a coverage factor of k=2, providing a level of confidence of approximately 95%)

**\*‡ DIFFERENTIAL PRESSURE (BREATHABILITY)**

EN 14683:2019+AC 2019

Sample: 1

Acceptable result <60%

RESULT

<20 Pa/cm<sup>2</sup>

Test Conditions:

Temperature: 21±5°C Humidity: 75±5%

Number and general location of the areas of the mask the differential measurements were taken: Test performed with the direction of flow from the inside to the outside. Side and central location.

Air flow rate: 8 L/min

Dimensions of the test specimens: 4.9cm<sup>2</sup> (5 test specimens)

Test specimen 1 (<20 LQ), Test specimen 2 (<20 LQ), Test specimen 3 (<20

LQ), Test specimen 4 (<20 LQ), Test specimen 5 (<20 LQ)

Remark:

**TEST REPORT NUMBER:** PRTT00075961

Page 3 of 4

Sample: 1

Acceptable result <60%

RESULT

The tests were performed after 5 washing cycles according to ISO 6330:2012

Type of machine: Front loading

Washing procedure: 4N, 40°C

Drying procedure: Tumble Dry

Detergent used: ECE Type A + Sodium Perborate + TAED

Total dry mass (kg): 2

Ballast used: 100% Polyester

